

This drawing is copyright and should not be reproduced without permission. Scaled dimensions should not be taken from this drawing.

DO NOT SCALE FROM DRAWING
Fixers Note:-
All dissimilar materials to be isolated
Do not change fixing types or centres without prior permission from the Design Department
IF IN DOUBT - ASK!

- C4 AS BUILT ISSUE 29.08.12
- C3 CONSTRUCTION ISSUE 16.12.11
Fittings altered- Mail spec added
- C2 CONSTRUCTION ISSUE 16.12.11
Fischer Bolt altered As per SE calls
- C1 CONSTRUCTION ISSUE 21.11.11
Brackets Altered As per SE calls
- C0 CONSTRUCTION ISSUE 21.10.11
Soffit spec developed.
- P2 EPDM altered as to show alignment with jamb EPDM NET/Cladtech cont. 17/8 & 25/8
- P1 Concrete altered, u/s lower due to step in upper surface to meet NHBC requirements. Door position altered. Head brackets altered.

Rev.	Amendments	Date
DRAWING STATUS		
AS BUILT ISSUE		

Contract: Riverside Quarter Phase 3

Client: Galliford Try Construction

Drawing Title: Sliding Door to Wintergarden Schuur ASS70 H1 Head Detail - Bldg 5a (2 to 4) & 5b (2 to 6)

Drawn by: SL
Date: June 11
Scale: 1:20

Contract No.	Drawing No.	Rev
C1065	D101	C4

CONCRETE TOLLERANCE +/- 10mm IN ANY DIRECTION

METAL DRYLINER CHANNEL FIXED TO CONCRETE.
50mm KINGSPAN TF70 RIGID INSULATION
DRY LINER CHANNEL FIXED TO CORRECT LEVEL.
12.5mm LAFARGE-GTEC AQUABOARD
19mm ST/STEEL DRYWALL SCREWS
JOINTS SEALED WITH AQUA MIX & PAPER TAPE
PAINTED BY OTHERS.

EPDM SET BACK AT END OF FRAMES TO ENABLE OVERLAP TO JAMB AND MEMBRANES TO BE IN THE SAME PLANE...

250mm x 1mm TRELEBORG EPDM SEALED TO CONCRETE WITH 298680 ADHESIVE & PRIMER (IF NECESSARY) DRESSED INTO HEAD OF FRAME TO MEET JAMB EPDM.

75x50x3 GALV STEEL BRACKET @900MM LONG - NOT WITHIN 98mm OF CORNERS TO ALLOW EPDM TO LAP WITH JAMB EPDM.
55x55x3 GALV STEEL ANGLE BRACKET @100mm WIDE @ MAX 400 C/C

FISCHER 8/30 FAZII ST/ST/4 ANCHOR BOLT
MAX FIXTURE=30mm
MIN HOLE DEPTH=85mm
MIN SPACING=50mm
MIN EDGE=100mm
TORQUE 20Nm
USE PACKING SHIMS IF CONCRETE LEVEL IS HIGH.

4X30 BZP PAN POZI & PLUG

27X7 SLOT IN BRACKET TO TAKE 10mm LIVE LOAD MOVEMENT
M6 X 25 BZP BOLT, LOCK NUT AND WASHER (NYLON & BZP) PINCH TIGHT 400 CTR MAX

4.2 X 19 PAN POZI ST/STEEL SCREWS.
SOFT CAULKING SEAL BY GT.

CEILING BY GALLIFORD TRY

- 148450 OUTERFRAME (RAL9007)
- 359700 DRIP (RAL9007)
- 333510 GUIDE TRACK (RAL9007)
- 333490 LOCATING PROFILE (MILL)
- 244815 COVER (BLACK PVC)
- 244845 PVC GUIDE.
- 148550/430060 SASH PROFILE (RAL9007 BOTH SIDES)
- 244845 PVC GUIDE.
- 284351 4mm GLAZING GASKET
- LINE OF EPDM AT JAMB
- 359700 TRIM (RAL9007)
- 333510 GUIDE TRACK (RAL9007)
- 244830 WEATHER GASKET
- 203102 BEAD CLIP
- 184050 22mm BEAL (RAL9007)
- WEDGE GASKET

